

C34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2024/School/1189

Dated: 13/12/2024

FIRE SAFETY CERTIFICATE

Certified that the building Dayanand Model School Located at Arya Samaj Premises, West Patel Nagar, New Delhi-110008, comprised of Ground + 02 Upper floors have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi circular No: 3298-3398 Dated 01/03/2011 and verified by the officer concerned from this department on 29/11/2024 in the presence of Ms Richa Dhawan (Principal) and that the premises is fit for occupancy class B "Educational building" with effect from 13/12/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/12/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
13/12/24


Copy to:

1. The Principal, Dayanand Model School Located at Arya Samaj Premises, West Patel Nagar, New Delhi-110008.
2. The, Directorate of Education Old Secretariat Delhi - 110054

Condition for the validity of fire safety certificate:-

- 1 The widths of class room doors must be extended to 01 mtr within 4 months otherwise FSC shall be null & void.
- 2 The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void.
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 5 The trained staff should be available round the clock.
- 6 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 7 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 8 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in
- 9 Basement if any shall be used strictly as per building bye laws.
- 10 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.


Off. Principal
Dayanand Model School
Patel Nagar, New Delhi-110008


Manager
Dayanand Model School
Patel Nagar, New Delhi-110008